

CLARIFICATIONS

Procurement Process:	ECMWF Procurement - Request for Proposal
Reference of Procurement:	ECMWF/2025/RFP/397
Title of Procurement:	Provision and installation of an additional chiller unit at ECMWF Data Centre in Bologna, Italy.
Edition:	1st edition
Date of Issue:	05/11/2025

Issued by ECMWF Administration Department, Procurement Section

#	Category	Question	Answer by ECMWF	Date - answer is published by ECMWF
1	Volume II - Specification and Requirements	Could you please confirm the nominal cooling capacity of the chiller?	921 kW	05/11/2025
2	Volume II - Specification and Requirements	Which refrigerant gas is required for the unit?	R513A	05/11/2025
3	Volume II - Specification and Requirements	Does the supply and installation cost of the chiller include the crane service for lifting it to the roof?	Yes it does.	05/11/2025
4	Volume II - Specification and Requirements	Is the activity required to be carried out while keeping the existing chillers and cooling circuits operational?	Yes	05/11/2025
5	Volume II - Specification and Requirements	ECMWF must be available for an on-site inspection.	ECMWF confirms availability.	05/11/2025
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				